

10-DEC-2007 Notification - Change in Registrant Address

**OxyChem®
Towerchlor® 90 Tablets
Microbiocide**

STABILIZED CHLORINATING TABLETS

READ THE LABEL BEFORE USING

COMMERCIAL

Microbiocide for control of organic slimes of algae, bacteria and fungi in recirculation water of condensing and cooling equipment.

**REGISTRATION NO. 22096
PEST CONTROL PRODUCTS ACT**

GUARANTEE:

Available chlorine present as trichloro-s-triazinetriene 90%

CAUTION

POISON



CORROSIVE

Lot No.:

NET CONTENTS 22.7 kg. (50 lbs.)

**Occidental Chemical Corporation
PO BOX 809050
DALLAS TX 75380-9050
972-404-3800**

HMIS RATING SYSTEM: Health 3 Flammability 0 Reactivity 2

**OXYCHEM 24 HOUR EMERGENCY PHONE: 1-800-733-3665 or 972-404-3328
CHEMTREC EMERGENCY PHONE: 1-800-424-9300**

DIRECTIONS FOR USE

RECIRCULATING WATER SYSTEMS

Towerchlor 90 7.6 cm Tablets aid in the control of bacterial, fungal and algal slimes in evaporative condensers, heat exchange water systems, commercial and industrial cooling towers, ornamental fountains, influent systems such as flow through filters, lagoons, industrial scrubbing systems. This product may be added to the system continuously or intermittently as needed with a wide variety of tablet dissolving devices (feeders, bags, buckets, etc.) or by direct placement of tablets into the water at a point where the dissolved tablets will be uniformly mixed. The frequency of feeding and duration of the treatment will depend on the severity of the contamination. Badly fouled systems must be cleaned before treatment is begun.

FOR CONTROL OF BACTERIA, FUNGI AND ALGAE

Intermittent or slug method

INITIAL DOSE: When the system is noticeably fouled, add Towerchlor 90 7.6 cm Tablets at the rate of 0.6 to 1.2 kgs (3-6 tablets) per 10,000 liters of water (60-120 ppm) in the system to achieve 1-5 ppm total residual halogen as chlorine, as measured by a suitable test kit. Repeat dosage until residual is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add Towerchlor 90 7.6 cm Tablets at the rate of 0.12 to 0.6 kgs (1/2-3 tablets) per 10,000 liters (12-60 ppm) in the system to maintain 1 ppm total residual halogen as chlorine, as measured by a suitable test kit. Repeat dosage until residual is achieved.

Continuous feed method

INITIAL DOSE: When the system is noticeably fouled, add Towerchlor 90 7.6 cm Tablets at the rate of 0.6 to 1.2 kgs (3-6 tablets) per 10,000 liters (60-120 ppm) in the system to achieve 1-5 ppm total residual halogen as chlorine, as measured by a suitable test kit. Repeat dosage until residual is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add Towerchlor 90 7.6 cm Tablets at the rate of 0.12 to 0.6 kgs (1/2-3 tablets) per 10,000 liters (12-60 ppm) in the system to maintain 1 ppm total residual halogen as chlorine, as measured by a suitable test kit. Repeat dosage until residual is achieved.

NOTICE TO USER

This pest control product is to be used only in accordance with the directions on the label. It is an offense under the *Pest Control Products Act* to use this product in a way that is inconsistent with the directions on the label. The user assumes the risk to persons or property that arises from any such use of this product.

PRECAUTIONS

- KEEP OUT OF REACH OF CHILDREN.
- Strong oxidizing agent. May cause fire or explosion if contaminated.
- Dangerous gas formed when mixed with acid.
- Do not mix with any other chemical.
- Avoid contact with skin and eyes.
- Harmful if swallowed.
- Keep container closed and store in a cool, dry location.
- Wear chemical resistant gloves, long pants, a long sleeved shirt, and shoes when handling this product.

FIRST AID

If splashed in eyes, hold eye open and rinse slowly and gently with water for 15–20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice. On skin, flush thoroughly with water for 15 minutes. If on skin or clothing, take off contaminated clothing. Rinse skin immediately with plenty of water for 15–20 minutes. Call a poison control centre or doctor for treatment advice. If swallowed, call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person. Take container, label or product name and Pest Control Product Registration Number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION: Treat symptomatically.

ENVIRONMENTAL HAZARDS

This product is toxic to fish and other aquatic organisms. It is not to be used in circumstances that would cause or allow it to enter lakes, streams, ponds, estuaries, oceans or other waters in contravention of federal or provincial regulatory requirements. The requirements of applicable laws should be determined before using the product.

DISPOSAL

1. Triple or pressure-rinse the empty container. Add the rinsings to the treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on the disposal of unused, unwanted product, contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill, and for cleanup of spills.

® OxyChem and Towerchlor are registered trademarks of Occidental Chemical Corporation

This label transcript service is offered by the Pest Management Regulatory Agency to provide efficient searching for label information. This service and this information do not replace the official hard-copy label. The PMRA does not provide any guarantee or assurance that the information obtained through this service is accurate, current or correct, and is therefore not liable for any loss resulting, directly or indirectly, from reliance upon this service.