

2024-2103
2024-11-21

This label has been updated according to the re-evaluation decision for Potassium Dimethyldithiocarbamate, SRD2024-01. While users are encouraged to follow this updated label immediately, the previously approved label is valid until 2026-02-26 in accordance with the phase out period set out in the re-evaluation decision for Potassium Dimethyldithiocarbamate, SRD2024-01. This previously approved label will be provided upon request by emailing hc.pmra.info-arla.sc@canada.ca. In your email please include the product name and Registration number of the label you are requesting.

2024-2103
2024-11-21

[WETCIDE 4210 Label Centre Panel – May 7 2024]

Wetcide 4210

LIQUID MICROBICIDE
INDUSTRIAL
READ THE LABEL BEFORE USING

ACTIVE INGREDIENT:
Potassium dimethyldithiocarbamate... 10% (by weight)

REGISTRATION NO.: 22457
PEST CONTROL PRODUCT ACT


NET CONTENTS: 1 to 205 liters

WARNING

POISON



CORROSIVE



CORROSIVE TO EYES
SKIN IRRITANT
POTENTIAL SKIN SENSITIZER

ENVIRONMENTAL HAZARDS: Toxic to aquatic organisms. Keep out of lakes, streams or ponds.

NOTICE TO USER: This pest control product is to be used only in accordance with the directions on the label. It is an offense under the Pest Control Products Act to use this product in a way that is inconsistent with the directions on the label.

Water Energy Technologies
3375 North Service Rd. #A7.
Burlington, Ontario L7N 3G2
Tel: 905-336-7666

2024-2103
2024-11-21
[WETCIDE 4210 Label Left Panel – March 1 2024]

CONTROLS THE GROWTH OF ALGAE, BACTERIA AND FUNGI

DIRECTIONS FOR USE

1) Cooling Tower Systems:

Prior to use in water cooling towers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 800 to 1200 mL per 10,000 liters of water should then be added to the sump of the cooling water towers. Repeat the initial dosage until control is evident. Subsequent slug additions of 400 to 1200 mL per 10,000 liters of water should be added every 2 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem.

2) Industrial Air Washing Systems:

Prior to use in air washers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 186 to 236 mL per 1,000 liters of water should then be added to the sump or the water collector trays. Repeat the initial dosage until control is evident. Subsequent slug additions of 86 to 236 mL per 1,000 liters of water should be added every 1 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem. For use only in systems equipped with effective mist eliminating components.

DO NOT discharge effluent containing this product into sewer systems, lakes, streams, ponds, estuaries, oceans or other waters. DO NOT contaminate irrigation or drinking water supplies or aquatic habitats by cleaning or equipment or disposal of wastes.

LOT # 4210-xxxxxx

[Rev2024/05]

2024-2103
2024-11-21

[WETCIDE 4210 Label Right Panel – March 1 2024]

PRECAUTIONS

WARNING

KEEP OUT OF REACH OF CHILDREN

Corrosive to the eye. DO NOT get in eyes. Corrosive to skin. DO NOT get on skin. Potential skin sensitizer. Harmful if swallowed. Avoid contact with clothing and the contamination of food. Wear a long-sleeved shirt, long pants, chemical-resistant gloves, protective eyewear (goggles or face shield), socks and shoes when handling the concentrated product or treated process fluids and during clean-up and repair. Remove and wash contaminated clothing before re-use. For use with closed loading and transfer systems only (i.e., dry coupling). A closed transfer system is defined as a procedure for removing a pesticide from its original container, rinsing the emptied container and transferring the pesticide and rinse solution through connecting hoses pipes, and coupling that are sufficiently tight to prevent exposure of any person to the pesticide or rinse solution. Furthermore, the closed transfer system must be equipped with a dry coupling system that is designed to drip less than 2 mL per coupling.

FIRST AID

If in eyes: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice. If on skin or clothing: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control centre or doctor for treatment advice. If inhaled: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice. If swallowed: Call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person. Take container, label, or product name and Pest Control Product Registration Number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION: Note to physician: Probable mucosal damage following ingestion may contraindicate gastric lavage. Treat symptomatically.

DISPOSAL

1. Triple- or pressure-rinse the empty container. Add the rinsings to the treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on the disposal of unused, unwanted product, contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill, and for clean-up of spills.